



307 E Jefferson St Monroe, NC
28112

Dan Larres

 facilitiesbids@ucps.k12.nc.us
ucps.k12.nc.us

Purchasing and Contracts

Addendum #1

BID#: 5-97648046

Marshville Elementary School Generator Replacement

DUE DATE: July 30, 2025 at 10:00 AM

Contractor shall fulfill all requirements listed within the bid documents, including additions and changes noted below.

Please see the questions below for Addendum #1.

1. What is the fuel tank size on the generator? **It will be a diesel generator; the contractor will be responsible for the size of the generator and fuel capacity for this service.**
2. Is it a 100 Amp? **The generator will be feeding the 100 amp circuit in the outside electrical room. Transfer switch can be on the outside of the electrical closet.**

End of Addendum #1