

Client Sample Results

Client: Union County Public Schools
Project/Site: Lead in Drinking Water - Rocky River E.

Job ID: 680-204823-1

Client Sample ID: Rocky River E. 1

Lab Sample ID: 680-204823-1

Date Collected: 09/11/21 09:25

Matrix: Water

Date Received: 09/22/21 13:30

Method: 200.8-1994 R5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.060	U	0.30	0.060	ug/L		09/23/21 15:42	09/24/21 22:14	1

Client Sample ID: Rocky River E. 2

Lab Sample ID: 680-204823-2

Date Collected: 09/11/21 09:30

Matrix: Water

Date Received: 09/22/21 13:30

Method: 200.8-1994 R5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.18	J	0.30	0.060	ug/L		09/23/21 15:52	09/25/21 19:41	1

Client Sample ID: Rocky River E. 3

Lab Sample ID: 680-204823-3

Date Collected: 09/11/21 09:35

Matrix: Water

Date Received: 09/22/21 13:30

Method: 200.8-1994 R5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.060	U	0.30	0.060	ug/L		09/23/21 15:42	09/24/21 21:31	1

Client Sample ID: Rocky River E. 4

Lab Sample ID: 680-204823-4

Date Collected: 09/11/21 09:39

Matrix: Water

Date Received: 09/22/21 13:30

Method: 200.8-1994 R5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.060	U	0.30	0.060	ug/L		09/23/21 15:42	09/24/21 21:26	1

Client Sample ID: Rocky River E. 5

Lab Sample ID: 680-204823-5

Date Collected: 09/11/21 09:44

Matrix: Water

Date Received: 09/22/21 13:30

Method: 200.8-1994 R5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.068	J	0.30	0.060	ug/L		09/23/21 15:42	09/24/21 21:49	1

Client Sample ID: Rocky River E. 6

Lab Sample ID: 680-204823-6

Date Collected: 09/11/21 09:49

Matrix: Water

Date Received: 09/22/21 13:30

Method: 200.8-1994 R5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.077	J	0.30	0.060	ug/L		09/23/21 15:52	09/25/21 19:23	1

Client Sample ID: Rocky River E. 7

Lab Sample ID: 680-204823-7

Date Collected: 09/11/21 09:51

Matrix: Water

Date Received: 09/22/21 13:30

Method: 200.8-1994 R5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	J	0.30	0.060	ug/L		09/23/21 15:42	09/24/21 21:44	1

Client Sample Results

Client: Union County Public Schools
Project/Site: Lead in Drinking Water - Rocky River E.

Job ID: 680-204823-1

Client Sample ID: Rocky River E. 8

Lab Sample ID: 680-204823-8

Date Collected: 09/11/21 09:53

Matrix: Water

Date Received: 09/22/21 13:30

Method: 200.8-1994 R5.4 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.10	J	0.30	0.060	ug/L		09/23/21 15:42	09/24/21 21:24	1

Client Sample ID: Rocky River E. 9

Lab Sample ID: 680-204823-9

Date Collected: 09/11/21 09:57

Matrix: Water

Date Received: 09/22/21 13:30

Method: 200.8-1994 R5.4 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.093	J	0.30	0.060	ug/L		09/23/21 15:42	09/24/21 22:16	1

Client Sample ID: Rocky River E. 10

Lab Sample ID: 680-204823-10

Date Collected: 09/11/21 09:59

Matrix: Water

Date Received: 09/22/21 13:30

Method: 200.8-1994 R5.4 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.060	U	0.30	0.060	ug/L		09/23/21 15:42	09/24/21 22:06	1

Chain of Custody Record

eurofins
| Environment Testing
America

Client Information

Client Contact: Craig Reeder

Phone: 704-288-7302

Company: Union County Public Schools

Sample ID: John Torpice

E-Mail: craig.reeder@ucps.k12.nc.us

Center Tracking Info: 690-118963-45180.3

Address: 400 N Church St

City: Charlotte

State, Zip: NC, 28110

Phone: 704-288-7302

Email: craig.reeder@ucps.k12.nc.us

Project Name: Lead in Drinking Water

Site: SSOMR

Date Data Requested: 7/23/08

TAT Requested (days): 7

PO #: PR11089204

W/O #: 69023474

Project #: 69023474

SSOMR: 69023474

Sample Identification

Sample ID	Sample Date	Sample Time	Sample Type (C=Composite, G=Grab)	Matrix (Inorganic, Organic, Inorganic/Organic)
1. Rocky River 3 compartment sink	4-6-21	7:23A	G	Water
2. Rocky River Food Prep sink	4-6-21	7:31A	G	Water
3. Rocky River Steamer	4-6-21	7:34A	G	Water
4. Kettle Rocky River	4-6-21	7:37A	G	Water
5. Raising Pan Rocky River	4-6-21	7:40A	G	Water

Analysis Requested

200.8 • (MOD) Total Lead

690-197607 Chain of Custody

Possible Hazard Identification

☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☐ Unknown ☐ Radiochemical

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/Note:

Sample Disposed (A fee may be assessed if samples are retained longer than 1 month)

☐ Return To Client ☐ Disposed By Lab ☐ Archive For Months

Special Instructions/OC Requirements:

Empty Kit Relinquished by:

Relinquished by:

Relinquished by:

Custody Seal Intact: ☒ Yes ☐ No

Date:

Date/Time:

Date/Time:

4/12/12 #27

Company:

Company:

Company:

Company:

Preservation Codes:

A - HCL

B - H2O

C - Zn Acetate

D - H2SO4

E - H2SO4

F - H2O

G - Another

H - Ascorbic Acid

I - Ice

J - DI Water

K - EDTA

L - EDTA

M - Hexane

N - None

O - As2O3

P - Na2CO3

Q - Na2SO3

R - Na2SO4

S - H2SO4

T - TSP Dodecylsulfate

U - Acetone

V - H2O

W - pH 4.5

Z - other (specify)

Other:

Special Instructions/Note:

1. 3 Compartment Sink
2. Food Prep Sink
3. Steamer
4. Kettle
5. Braising Pan



A-1.0

REVISIONS
1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

DATE: 12 DEC 2014
 SCALE: NOT SCALED
 PROJECT DESCRIPTION: PROPERTY ACCOUNTING

FLOOR PLAN

ROCKY RIVER
 ELEMENTARY SCHOOL
 500 ROCKY RIVER RD
 MONROE, NC 28110

UCPS
 UNION COUNTY PUBLIC SCHOOLS
 Globalization. Innovation. Graduation.

Client Sample Results

Client: Union County Public Schools
Project/Site: Lead in Drinking Water - Rocky River

Job ID: 680-197607-1

Client Sample ID: Rocky River 3 Compartment Sink

Date Collected: 04/06/21 07:28

Date Received: 04/14/21 12:30

Lab Sample ID: 680-197607-1

Matrix: Water

Method: 200.8-1994 R5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.32		0.30	0.060	ug/L		04/15/21 12:19	04/15/21 14:22	1

5

Client Sample ID: Rocky River Food Prep Sink

Date Collected: 04/06/21 07:31

Date Received: 04/14/21 12:30

Lab Sample ID: 680-197607-2

Matrix: Water

Method: 200.8-1994 R5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.13	J	0.30	0.060	ug/L		04/15/21 12:19	04/15/21 14:25	1

Client Sample ID: Rocky River Steamer

Date Collected: 04/06/21 07:34

Date Received: 04/14/21 12:30

Lab Sample ID: 680-197607-3

Matrix: Water

Method: 200.8-1994 R5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.25	J	0.30	0.060	ug/L		04/15/21 12:19	04/15/21 14:28	1

Client Sample ID: Kettle Rocky River

Date Collected: 04/06/21 07:37

Date Received: 04/14/21 12:30

Lab Sample ID: 680-197607-4

Matrix: Water

Method: 200.8-1994 R5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.33		0.30	0.060	ug/L		04/15/21 12:19	04/15/21 14:31	1

Client Sample ID: Braising Pan Rocky River

Date Collected: 04/06/21 07:40

Date Received: 04/14/21 12:30

Lab Sample ID: 680-197607-5

Matrix: Water

Method: 200.8-1994 R5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.17	J	0.30	0.060	ug/L		04/15/21 12:19	04/15/21 14:34	1

Eurofins TestAmerica, Savannah



FLOOR PLAN

PAGE TITLE:
PROPERTY ACCOUNTING
PROJECT DESCRIPTION:

DATE: 12 DEC 2014

REVISIONS:
△
△
△

SCALE: NOT SCALED

A-1.0